Active Ventilation Products Inc.

TEST REPORT

SCOPE OF WORK

This report gives the results of air leakage and flow rate testing on a vent. The sample was selected and supplied by the client and was received at the laboratories on:

July 16, 2024

The sample appeared to be in new unused condition upon receipt.

MODEL NUMBER

RBV-9-C4-TP

Round Back Vent, 9" Diameter, 4" Collar & Tail Pipe Residential Roof Jack Vent Cap for Exhaust Duct Applications

PROJECT NUMBER

G105373987

REPORT NUMBER

105373987CRT-007b

ISSUE DATE July 29, 2024

REVISED DATE

10/1/2024

TEST DATE

July 16 - 24, 2024

DOCUMENT CONTROL NUMBER

DIFF.PKT.2022 © 2022 INTERTEK





3933 US RT 11 Cortland, NY 13045 Telephone: (607) 753-6711

www.intertek.com

REPORT NUMBER 105373987CRT-007b

MODEL NUMBER(s)

RBV-9-C4-TP, Round Back Vent, 9" Diameter, 4" Collar & Tail Pipe

REPORT RENDERED TO:

Active Ventilation Products Inc. 311 1st Newburgh, NY 12550

		ΓΙΟΝ

The testing performed was authorized by signed quote number Qu-01330540-7.

TEST STANDARDS

ANSI/AMCA Standard 500-L-23, entitled "Laboratory Methods of Testing Louvers for Rating".

In Charge of Testing:

Joey Esce Project Engineer Acoustical Testing Reviewer:

Brian Cyr Engineer Acoustical Testing

Dim Cy

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Page 2 of 5 7/29/2024



3933 US RT 11 Cortland, NY 13045

Telephone: (607) 753-6711 www.intertek.com

SAMPLE INFORMATION

REPORT NO. 105373987CRT-007B

ITEMS RECEIVED

Item No.	Control No.	Model No.	Description	Received	
1	CRT2407161020-007	RBV-9-C4-TP	Round Back Vent, 9" Diameter	July 16, 2024	

DESCRIPTION OF TEST SPECIMEN

The sample consisted of an exhaust vent cap. The inlet measured 8-3/4 inches in diameter and the vent cap measured 12-1/4 inches in diameter. The gap between the cap and collar was measured to be 1-5/16 inch.

SAMPLE PHOTOS







TEST METHODS

Air Performance testing was conducted in accordance with ANSI/AMCA Standard 500-L-23, entitled "Laboratory Methods of Testing Louvers for Rating"

Air Volume was measured employing metering stations containing appropriately sized orifice plates.

Page 3 of 5 7/29/2024



3933 US RT 11 Cortland, NY 13045

Telephone: (607) 753-6711 www.intertek.com

RESULTS OF TESTS

REPORT NO. 105373987CRT-007B


AIR PERFORMANCE
RBV-9-C4-TP, Round Back Vent, 9" Diameter, 4" Collar & Tail Pipe

Pressure Drop	Pressure Drop Across Vent Cap		Airflow Volume
in. H₂O	<u>Pa</u>	<u>fpm</u>	<u>SCFM</u>
0.080	20	403	178
0.200	50	597	264
0.360	90	796	352
0.560	139	1000	442
0.660	164	1190	526
0.910	226	1405	621
1.100	274	1593	704
1.400	348	1808	799
1.700	423	2000	884
2.000	498	2199	972

fpm = feet per minute

in. H20 = inches of water

scfm = standard cubic feet per minute



Page 4 of 5 7/29/2024



3933 US RT 11 Cortland, NY 13045

Telephone: (607) 753-6711

www.intertek.com

EQUIPMENT LIST

REPORT NO. 105373987CRT-007B

#	Equipment	Model No	Control No.	Last Cal	Cal Due
5	Manometer Incline	424-5	F166	3/5/2024	3/5/2025
6	Manometer Incline	424-5	F167	3/5/2024	3/5/2025
7	RTD Pair	78N01N00N040B3	T1440/1	6/12/2024	6/12/2025
8	Barometer	PTB110	P1063	6/12/2024	6/12/2025
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

Remarks:

Test Conditions During Testing:

Drybulb Temperature: 79.3°F Wetbulb Temperature: 69.8°F Barometric Pressure: 28.6 in. Hg

Page 5 of 5 7/29/2024